



केन्द्रीय चिड़ियाघर प्राधिकरण
Central Zoo Authority

(STATUTORY BODY UNDER THE MINISTRY OF ENVIRONMENT & FORESTS, GOVT. OF INDIA)

520 2 copies

241

Dr. B. R. SHARMA
MEMBER SECRETARY

Bikaner House, Annexe VI,
Shahjahan Road, New Delhi - 110011
website : <http://www.cza.nic.in>

F. No. 19-62/92-CZA(27)(Vol.IV)(M)

DATE: 28.11.2008

To

The Divisional Forest Officer
Assam State Zoo Division,
Guwahati - 5 (Assam).

**Sub:- Development of Assam State Zoo cum Botanical Garden,
Guwahati.**

Sir,

Please refer to your letter No. Z/CZA/Proposal/2008-2009/2551 dated 6.9.2008.

The design of the proposed construction of different enclosures in the Assam State Zoo cum Botanical Garden, Guwahati or the development of the zoo were scrutinized by the Expert Group on Zoo Designing of the Central Zoo Authority in its meeting held on 21st November, 2008. The observations made by the Expert Group Members are reproduced below:-

(i) Construction of off-display conservation breeding centre for Golden langur

The design was not approved. The members suggested that the following amendment should be carried out and the revised design should be submitted for the further consideration of the Central Zoo Authority:-

- (a) The covered tent like structure using stainless steel mesh with maximum height of 10 meter may be provided which should be ensured that any point the height of the enclosure should not be less than 4 meters.
- (b) The tress within the enclosure retained by providing appropriate ring the sample design by the Members is provided to draw up the revised design.

Dr. B. R. Sharma

- (ii) **Construction of cubicles in the Clouded leopard enclosure along with the service yard and footpath and painting of the existing enclosure**

The Expert Group Members approved the design subject to that the D-3 cubicle should be operated by a pulley.

- (iii) **Construction of footpath and stand off barrier in the existing Lion enclosure**

The design was approved.


- (iv) **Construction of the project office for Conservation Breeding Programmes**






The design was approved subject to that the following amendments should be carried out and revised design should be submitted for the records of the Central Zoo Authority:-

- (a) The plinth area (covered area) in the project office should be limited to 50 sq. meter with 2 multipurpose room and one toilet.
(b) The cost of the construction should not exceed more than Rs. 7.5 lakhs.

Yours faithfully,
sd/-
(B. R. Sharma)
Member Secretary

Copy to the Chief Wildlife Warden, Government of Assam, Guwahati for favour of information & necessary action.


(B. R. Sharma)
Member Secretary



ROOF PLAN



Submitted
 1000/15
 Range Officer,
 Assam State Zoo
 H.O. Range

PROPOSED PROJECT OFFICE
 FOR CONSERVATION BREEDING PROGRAM
 ASSAM STATE ZOO
 GUWAHATI